

## **SCHEDULE-II**

### **TECHNICAL SPECIFICATION OF L.T. POLE FUSE UNIT ON M.S. FLAT 50 X 5 MM FOR TRANSFORMER PROTECTION AGAINST T.S. No. DISCOM/EZ/PUR/89 DUE ON 14.02.2007.**

The L.T. Pole Fuse Unit on M.S. Flat 50x5 mm for Transformer Protection should have following features and as per enclosed drawing.

<b>S.No.</b>	<b>PARTICULARS</b>	<b>QTY (In Nos.)</b>
1.	M.S. Flat 50mm x 5 mm.	01
2.	Porcelain L.T. Post Insulator	07
3.	Nuts and Bolts with 2 Nos. Washer for above Post Insulators	14
4.	I Clip 19 x 5 mm. and 75 mm. long Aluminum Strip with 10 mm x 100 mm. Nut and Bolt with 2 Nos. washer.	07
5.	Back Clamp made of M.S. Flat 50 x 5 mm. suitable for 140 Kg./ 8 Meter long PCC Pole with 2 Nos. washer and 10 x 75 mm. Nut and Bolt.	01

**Chief Engineer (S&P-EZ)  
MPPKVCL : Jabalpur**